




# SUBMITTAL SHEET for Flexible Duct

## S-LP-10 Non-Insulated Flexible Air Duct Connector for Environmental Air Handling Systems

<b>CODES/STANDARDS</b>		Listed and labeled by Underwriters' Laboratories, Inc., as a Class I Connector, Standard 181. It complies with the latest NFPA Bulletins 90A and 90B. Flame spread: not over 25. Smoke developed: not over 50.										
<b>FABRIC TYPE</b>		Coated fiberglass woven fabric.										
<b>STEEL WIRE</b>		Coated spring steel wire helix.										
<b>SIZES, ID</b>		2	3	4	5	6	7	8	9	10	12	14
<b>LENGTH (feet)</b>		25 ft.										
<b>INSIDE BEND RADIUS (inches)</b>		2	3	4	5	6	7	8	9	10	12	14
<b>OPERATING TEMPERATURE RANGE</b>		0° F to 250° F.										
<b>RATED VELOCITY</b>		5000 fpm.										
<b>MAX RATED PRESSURE</b>	<b>POSITIVE</b>	All Sizes – 10" w.g.										
	<b>NEGATIVE</b>	All Sizes – 1" w.g.										



<b>JOB</b> _____	<b>P.O. NO.</b> _____
<b>LOCATION</b> _____	<b>JOB NO.</b> _____
<b>ENGINEER</b> _____	<b>REPRESENTATIVE</b> _____
<b>CONTRACTOR</b> _____	
Certified Correct	Approved for Construction
<b>BY</b> _____	<b>BY</b> _____
<b>TITLE</b> _____	<b>TITLE</b> _____
<b>DATE</b> _____	<b>DATE</b> _____

**THERMAFLEX®** – A Division of Flexible Technologies, Inc., a subsidiary of Smiths Group plc.

Customer Service Departments:

- 528 Carwellyn Rd. • Abbeville, SC 29620 • 864-459-5441
- 9101 Perkins St. • Pico Rivera, CA 90660 • 562-801-1634
- 1040A Jayson Court • Mississauga, Ontario L4W 2V5 • 905-602-9660

