

Submittal Data: BRC7E83

Individual Zone Controller Infrared Remote Controller


| Job Name: | Location: |
|-------------------------------|--------------------------------------|
| Purchaser: | |
| Engineer: | |
| Submitted To: | For: Reference Approval Construction |
| Submitted By: | Date: |
| Unit Designation: Schedule #: | Model No.: |

For use with the following Daikin VRV Model: FXHQ For use with the following Daikin SkyAir Model: FHQ

| 1 group/maximum o | f 16 units controllable. |
|---------------------------------------|-----------------------------|
| • Simple, compact an | d easy-to-operate unit. |
| | |
| OPERATION | Start/Stop |
| | Operation Mode |
| | Temperature Setting |
| | 60°F – 90°F Set Point Range |
| | Fan Speed |
| | Airflow Direction |
| MONITORING | Status |
| | Malfunction Flashing |
| | Malfunction Content |
| | Operation Mode |
| | Temperature Setting |
| | Fan Speed |
| | Airflow Direction |
| SCHEDULING | Auto ON/OFF Timer |
| CONTROL | Field Setting Mode |


Field Setting Mode


FEATURES / BENEFITS











MANAGEMENT