

## FEATURES

Small footprint (12"x12"x21") fits low crawl spaces, basement mechanical closets, or other small spaces

Sized to fit between floor joists for convenient hanging installation

Rotatable exhaust outlet provides for horizontal or vertical discharge

Exceeds ENERGY STAR® efficiency requirements

MERV-13 filter provides superior air filtration

Engineered for low temperature operation and the air flow issues that crawl spaces present

Ducting options for divided spaces

Auto restart allows the dehumidifier to automatically restart after a power outage

# ACCESSORIES

4027168	Pre-Filter	
4028524	Pre-Filter 12-Pack	
4030671	MERV-11 Filter (9" x 11" x 1")	
4027418	MERV-11 Filters 4-Pack + 1 Pre-Filter	
4030733	MERV-11 Filters 12-Pack	
4037724	MERV-13 Filter (9" x 11" x 1")	
4038839	MERV-13 Filters 4-Pack	
4037736	MERV-13 Filters 12-Pack	
4030113	Pump Kit	
4028616	Caster Kit	
4036695	Hang Kit	
4030203	Duct Kit, Supply Only	
4030204	Duct Kit, Return Only	
4027415	8" Flex Duct 25'	
4020177	8" Flex Insulated Duct 25'	
4020175	Remote Dehumidistat	





### **PRODUCT SPECIFICATIONS**

Part Number	4033600	4033600	
Blower	150 CFM @ 0.0" WG		
Power	580 watts @ 80°F and 60% RH		
Supply Voltage	115 volt – 1phase – 60 Hz		
Current Draw	5.1 amps		
Operating Temperature	49°F Min., 95°F Max.		
Crawl Space Sizing Very Tightly Sealed Moderately Sealed Some Leaks & Imperfections	Up to 3,000 Sq. Ft. (15,000 Cu. Ft.) Up to 2,200 Sq. Ft. (11,000 Cu. Ft.) Up to 1,800 Sq. Ft. (9,000 Cu. Ft.)		
Basement Sizing Very Tightly Sealed Moderately Sealed Some Leaks & Imperfections	Up to 2,000 Sq. Ft. (	Up to 2,300 Sq. Ft. (23,000 Cu. Ft.) Up to 2,000 Sq. Ft. (20,000 Cu. Ft.) Up to 1,800 Sq. Ft. (18,000 Cu. Ft.)	
Minimum Performance at Water Removal Efficiency Energy Factor	80°F and 60%RH 70 Pints/Day 5.0 Pints/kWh 2.4 L/kWh	70°F and 60%RH 47 Pints/Day 3.9 Pints/kWh 1.9 L/kWh	
Air Filter Size	MERV-13, Standard Pleat 9" x 11" x 1"		
Power Cord	9', 115 VAC, Ground		
Drain Connection	3/4" Threaded Female NPT		
Drain Hose	8' Direct Gravity Drain Hose (5/8" ID x 7/8" OD)		
Refrigerant	R410A, 15 oz.		
Unit Dimensions Shipping Dimensions		12"W x 12"H x 21"D 18"W x 18"H x 27"D	
Unit Weight Shipping Weight	55 lbs. 64 lbs.		



## INSTALLATIONS

#### **Supply Duct Kit**

Place the Santa Fe Compact2 in the unfinished area of the basement, near a drain access (condensate will drain via gravity or with an optional pump kit).

Using the supply duct collar, supply the dry air from the dehumidifier into a large, open area in the finished section of the basement

Place a return grill / passive vent on the other side of the wall that separates the finished and unfinished areas. This will allow for a circular air flow throughout the basement.

The passive grill will prevent the unfinished room from being placed under a negative pressure and also allow the dehumidifier to focus on keeping the unfinished area dry as well.

The onboard dehumidistat control can be used on the unit for this application or a 120 volt dehumidistat can be placed in the finished basement as well (we recommend using an electrician to run the wiring).

Be sure to keep all doors open to any other rooms in the basement to help with proper air circulation (bedrooms, bathrooms, etc.).

### Supply and Return Duct Kit

Place the Santa Fe Compact 2 in the unfinished area of the basement, near a drain access (condensate will drain via gravity or with an optional pump kit).

Using the supply and return duct kit, supply the dry air from the dehumidifier into a large, open area of the finished basement. Use the return duct kit to draw air back through the dehumidifier.

Be sure the return and supply are at least 10 feet away from each other for proper air flow throughout the basement. Add a passive grill between the finished and unfinished areas (\*or have a 2" gap under the door separating the two rooms). This will help keep the unfinished area dry as well.


Use the 120 volt, wall mounted dehumidistat for this installation for proper run time on the dehumidifier (we recommend using an electrician to install the separate 120 volt control).

Be sure to keep all doors open to any other rooms in the basement to help with proper air circulation (bedrooms, bathrooms, etc.).




## **Supply Duct Kit**

- (1)Passive Return Vent
- **Optional Wall Mount Dehumidistat**
- (3) Supply Grill
- Supply / Discharge Duct Work



# Supply and Return Duct Kit



2

2 24 

88 88

82 82 22 22 22